

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE**CERTIFICAT D'ESSAI OC**

Product
Produit

Name and address of the applicant
Nom et adresse du demandeur

Name and address of the manufacturer
Nom et adresse du fabricant

Name and address of the factory
Nom et adresse de l'usine

Note: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Trademark (if any)
Marque de fabrique (si elle existe)

Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais
constructeur

Model / Type Ref.
Ref. De type

Additional information (if necessary may also be
reported on page 2)
Les informations complémentaires (si nécessaire,,
peuvent être indiqués sur la 2^{ème} page

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

Electronic Controlgear for LED modules

SHANGHAI MOONS' AUTOMATION CONTROL CO LTD
BLDG 29, 4TH FL, CAOHEJING HI-TECH PARK, 69 GUIQING
RD, SHANGHAI , 200233, CHINA

SHANGHAI MOONS' AUTOMATION CONTROL CO LTD
BLDG 29, 4TH FL, CAOHEJING HI-TECH PARK, 69 GUIQING
RD, SHANGHAI, 200233, CHINA

SHANGHAI MOONS' AUTOMATION CONTROL CO LTD
168 MING JIA RD, MIN-HANG DISTRICT, SHANGHAI, 201107,
CHINA

Additional Information on page 2

Input: 100-240 V~, 50/60 Hz, 4.0 A max,

385 W max, ta 45°C,tc 88°C,   

Output: 14-32 Vdc , 13.3 A max, 320 W max, SELV
(See test report for variants)

MOONS'

MU320H1050AQx, MU320H1330AQx, MU320H600AQx,
MU320H800AQx
See Page 2

Additional Information on page 2

IEC 61347-1(ed.2), IEC 61347-1(ed.2);am1, IEC
61347-1(ed.2);am2, IEC 61347-2-13(ed.2)

4787174760.2.1-1 issued on 2016-04-01

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
 UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
 UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
 UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2016-04-06

Signature:

Jan-Erik Storgaard



Ref. Certif. No.

DK-53165-UL

Model Details:

MU320H1050AQx, MU320H1330AQx, MU320H600AQx, MU320H800AQx:

The variant "x" in model name could be blank, "_0-10V", or "_CP", to indicate different dimming function noted as below:

Blank: No dimming interface, output current could be adjusted by inside resistance

_0-10V: 0-10V dimming function and interface

_CP: 0-10V, PWM, Time control dimming function and interface

Additional Information:

Additionally evaluated to EN 61347-2-13:2014 used in conjunction with EN 61347-1:2008/A1:2011/A2:2013 and JIS C 8147-2-13:2014 used in conjunction with JIS C8147-1:2011. National Differences specified in the CB Test Report.

Additional information (if necessary)

Information complémentaire (si nécessaire)



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2016-04-06

Signature:

Jan-Erik Storgaard